



---

west virginia department of environmental protection

---

Division of Water and Waste Management  
601 57<sup>th</sup> Street, SE  
Charleston, WV 25304  
Phone: 304-926-0495 / Fax: 304-926-0463

Harold D. Ward, Cabinet Secretary  
dep.wv.gov

**MEMORANDUM**

**TO:** Katheryn Emery, P.E., Engineer Chief, DWWM

**FROM:** Corey McComas, DWWM

**DATE:** September 12, 2024

**SUBJECT:** Town of Monongah  
IJDC No. 2018S-1780  
Sanitary Sewer Improvements - Ph. II  
Use of Contingency Request

---

**RECOMMENDATION**

The Use of Contingency request for the above referenced project has been reviewed and is technically feasible.

**DISCUSSION**

The total costs of \$73,252.51 would expend a portion of the remaining \$84,127.75 remaining in the Construction Contingency line item. The remaining of \$10,875.24 is to be returned to IJDC. Neither the East nor West Side Pump Stations have spare pumps. These PSs have flow meters on their CSOs, but they have limited telemetry capabilities. The data from the CSO discharges is not being recorded by the current telemetry system. The new proposed telemetry system will allow the Town to see when their CSO's are discharging, when the pumps are on or off, pump run times, etc.

**QUESTIONS/COMMENTS**

- All parties agreed to the work and amount but a CO should be prepared for this work.
- Total was calculated to be \$73,252.51, not total in the request of \$72,178.00.