



---

west virginia department of environmental protection

---

Division of Water and Waste Management  
601 57<sup>th</sup> Street, SE  
Charleston, WV 25304  
Phone: 304-926-0495 / Fax: 304-926-0463

Harold D. Ward, Cabinet Secretary  
dep.wv.gov

### MEMORANDUM

**TO:** Katheryn Emery, P.E., Program Manager, DWWM

**FROM:** Dominique Madison, Technical Analyst, DWWM

**DATE:** September 11, 2026

**SUBJECT:** Town of West Union  
IJDC No. 2022W-2119  
Water System Improvements Project  
Budget Revision Request

---

### RECOMMENDATION

The Budget Request from the Town of West Union as submitted by Region VI, has been reviewed and is technically feasible.

### DISCUSSION

This budget revision seeks to utilize the remaining IJDC contingency of \$46,475. The request will be for installation of riprap approximately 15" thick on the slope at the WTP and from the existing culvert under the road to daylight at an approximate elevation of 784'. This revision will also install a 1' flat bottom rip-rap ditch at the toe of the slope. This work is needed to address unforeseen stormwater runoff from the upper roadway and continuous groundwater seepage along the cut slope.

The other revision's total cost will be \$220,000 and an increase of fifteen days of construction to install a control valve station, which will regulate water flow purchased from the Pennsboro water system. An interconnection has been completed, a water purchase agreement was executed, and the Town of West Union has begun receiving water.